

EXPEDITED PERMIT PROCESS FOR PV SYSTEMS SUPPLY-SIDE CONNECTION

The Solar America Board for Codes and Standards (Solar ABCs) Expedited Permit Process provides a means to differentiate systems that can be permitted quickly and easily due to their similarity with the majority of small-scale PV systems. Those systems with unique characteristics may be handled with small additions to this Expedited Permit Process or may require much more information, depending on the uniqueness of the installation.

The following pages contain forms for the Supply-Side Connection to use with the Expedited Permit Process. The Standard String, Micro-Inverter, and AC Module forms are also available as interactive PDF files at www.solarabcs.org/permitting. In jurisdictions that have adopted the Expedited Permit Process for PV Systems, these forms can be filled out electronically and submitted in either printed form and via email. An electronic format is used so that the supplied information is standardized and legible for the local jurisdiction.

SMALL-SCALE PV SYSTEMS SUPPLY- SIDE CONNECTION

* Please complete pages 2 thru 5 prior to applying for a permit.
* Provide (4) copies with your permit application at the permit center.

EXPEDITED PERMIT PROCESS FOR SMALL-SCALE PV SYSTEMS SUPPLY-SIDE CONNECTION

The information in this guideline is intended to help local jurisdictions and contractors identify when PV system installations are simple, needing only a basic review, and when an installation is more complex. It is likely that 50%-75% of all residential systems will comply with these simple criteria. For projects that fail to meet the simple criteria, resolution steps have been suggested to provide as a path to permit approval.

Required Information for Permit:

- 1. Site plan showing location of major components on the property. This drawing need not be exactly to scale, but it should represent relative location of components at site (see supplied example site plan). PV arrays on dwellings with a 3' perimeter space at ridge and sides may not need separate fire service review.
- 2. Electrical diagram showing PV array configuration, wiring system, overcurrent protection, inverter, disconnects, required signs, and ac connection to building (see supplied standard electrical diagram).
- 3. Specification sheets and installation manuals (if available) for all manufactured components including, but not limited to, PV modules, inverter(s), combiner box, disconnects, and mounting system.

Step 1: Structural Review of PV Array Mounting System

Is the array to be mounted on a defined, permitted roof structure? \Box Yes \Box No

If No due to non-compliant roof or a ground mount, submit completed worksheet for the structure WKS1.

Roof Information:

1. Is the roofing type lightweight (Yes = composition, lightweight masonry, metal, etc...)_____

If No, submit completed worksheet for roof structure WKS1 (No = heavy masonry, slate, etc...).

- 2. Does the roof have a single roof covering? \Box Yes \Box No
- If No, submit completed worksheet for roof structure WKS1.
 - 3. Provide method and type of weatherproofing roof penetrations (e.g. flashing, caulk)._____

Mounting System Information:

1. Is the mounting structure an engineered product designed to mount PV modules with no more than an 18" gap beneath the module frames? \Box Yes \Box No

If No, provide details of structural attachment certified by a design professional.

- 2. For manufactured mounting systems, fill out information on the mounting system below:
 - a. Mounting System Manufacturer _____ Product Name and Model#_____
 - b. Total Weight of PV Modules and Rails _____lbs
 - c. Total Number of Attachment Points_____
 - d. Weight per Attachment Point (b \div c)_____lbs (if greater than 45 lbs, see WKS1)
 - e. Maximum Spacing Between Attachment Points on a Rail ______inches (see product manual for maximum spacing allowed based on maximum design wind speed)
 - f. Total Surface Area of PV Modules (square feet)_____ ft^2
 - g. Distributed Weight of PV Module on Roof (b ÷ f)_____ lbs/ft² If distributed weight of the PV system is greater than 5 lbs/ft², see WKS1.

Step 2: Electrical Review of PV System (Calculations for Electrical Diagram)

In order for a PV system to be considered for an expedited permit process, the following must apply:

- 1. PV modules, utility-interactive inverters, and combiner boxes are identified for use in PV systems.
- 2. The PV array is composed of 4 series strings or less per inverter.
- 3. The total inverter capacity has a continuous ac power output 13,440 Watts or less
- 4. The ac interconnection point is on the load side of service disconnecting means (690.64(B)).
- 5. One of the standard electrical diagrams (E1.1, E1.1a, E1.1b, or E1.1c) can be used to accurately represent the PV system. Interactive PDF diagrams are available at www.solarabcs.org/permitting.

Fill out the standard electrical diagram completely. A guide to the electrical diagram is provided to help the applicant understand each blank to fill in. If the electrical system is more complex than the standard electrical diagram can effectively communicate, provide an alternative diagram with appropriate detail.

 \mathfrak{C}

Contractor Namo			Cite				
Address and Phone:			SILE	Plai	1		
	for Small-Scale, Single-Phase PV Systems					ns	
	Site Name:						
	Site Address						
		System AC	Size		_		
Drawn By:	SIZE	FSCM NO			DWG NO		REV
Checked By:	SCALE	NTS	Date:		SHEET		I

SUPPLY-SIDE CONNECTION ELECTRICAL DIAGRAM



NOTES FOR SUPPLY-SIDE CONNECTION ELECTRICAL DIAGRAM

PV MODULE RAT	INGS	@ STC	(Guide Section 5	;)
MODULE MAKE				

MODULE MODEL		
MAX POWER-POIN		
MAX POWER-POIN	,	
OPEN-CIRCUIT VC	,	
SHORT-CIRCUIT C		
MAX SERIES FUSE		
MAXIMUM POWER	v	
MAX VOLTAGE (T	(P 600V _{DC})	,
VOC TEMP COEFF		
IF COEFF SUPPLIE		

NOTES FOR ALL DRAWINGS:

OCPD = OVERCURRENT PROTECTION DEVICE

NATIONAL ELECTRICAL CODE® REFERENCES SHOWN AS (NEC XXX.XX)

INVERTER RATINGS (Guide Section 4)

INVERTER MAKE	
INVERTER MODEL	
MAX DC VOLT RATING	v
MAX POWER @ 40°C	w
NOMINAL AC VOLTAGE	v
MAX AC CURRENT	А
MAX OCPD RATING	A

SIGNS-SEE GUIDE SECTION 7

SIGN FOR DC DISCONNECT						
PHOTOVOLTAIC POWE	R SOURCE					
RATED MPP CURRENT	А					
RATED MPP VOLTAGE	V					
MAX SYSTEM VOLTAGE	V					
MAX CIRCUIT CURRENT	А					
WARNING: ELECTRICAL SHOCK HAZARD-LINE AND LOAD MAY BE ENERGIZED IN OPEN POSITION						
SIGN FOR INVERTER OCPD AND AC DISCONNECT (IF USED)						
AC POINT OF CON	NECTION					
AC OUTPUT CURRENT	A					
NOMINAL AC VOLTAGE	V					
THIS PANEL FED BY MULTIPLE SOURCES (UTILITY AND SOLAR)						

NOTES FOR ARRAY CIRCUIT WIRING (Guide Section 6 and 8 and Appendix D):

1.) LOWEST EXPECT AMBIENT TEMPERATURE BASED ON ASHRAE MINIMUM MEAN EXTREME DRY BULB TEMPERATURE FOR ASHRAE LOCATION MOST SIMILAR TO INSTALLATION LOCATION. LOWEST EXPECTED AMBIENT TEMP ______°C

2.) HIGHEST CONTINUOUS AMBIENT TEMPERATURE BASED ON ASHRAE HIGHEST MONTH 2% DRY BULB TEMPERATURE FOR ASHRAE LOCATION MOST SIMILAR TO INSTALLATION LOCATION. HIGHEST CONTINUOUS TEMPERATURE _____°C

2.) 2005 ASHRAE FUNDEMENTALS 2% DESIGN TEMPERATURES DO NOT EXCEED 47°C IN THE UNITED STATES (PALM SPRINGS, CA IS 44.1°C). FOR LESS THAN 9 CURRENT-CARRYING CONDUCTORS IN ROOF-MOUNTED SUNLIT CONDUIT AT LEAST 0.5" ABOVE ROOF AND USING THE OUTDOOR DESIGN TEMPERATURE OF 47°C OR LESS (ALL OF UNITED STATES),

a) 12 AWG, 90°C CONDUCTORS ARE GENERALLY ACCEPTABLE FOR MODULES WITH Isc OF 7.68 AMPS OR LESS WHEN PROTECTED BY A 12-AMP OR SMALLER FUSE.

b) 10 AWG, 90°C CONDUCTORS ARE GENERALLY ACCEPTABLE FOR MODULES WITH Isc OF 9.6 AMPS OR LESS WHEN PROTECTED BY A 15-AMP OR SMALLER FUSE.

NOTES FOR INVERTER CIRCUITS (Guide Section 8 and 9):

1) IF UTILITY REQUIRES A VISIBLE-BREAK SWITCH, DOES THIS SWITCH MEET THE REQUIREMENT? YES \square NO \square N/A \square

2) IF GENERATION METER REQUIRED, DOES THIS METER SOCKET MEET THE REQUIREMENT? YES \Box NO \Box N/A \Box

3) SIZE PHOTOVOLTAIC POWER SOURCE (DC) CONDUCTORS BASED ON MAX CURRENT ON NEC 690.53 SIGN OR OCPD RATING AT DISCONNECT

4) SIZE INVERTER OUTPUT CIRCUIT (AC) CONDUCTORS ACCORDING TO INVERTER OCPD AMPERE RATING. (See Guide Section 9)

5) TOTAL OF _____ INVERTER OCPD(s), ONE FOR EACH INVERTER. DOES TOTAL SUPPLY BREAKERS COMPLY WITH 120% BUSBAR EXCEPTION IN 690.64(B)(2)(a)? YES ___ NO ___

Contractor Name, Address and Phone:	Notes for One-Line Standard Electrical					
	Diagram for Single-Phase PV Systems					
	Site Name:					
	Site Address:					
	System AC Size:					
Drawn By:	SIZE	FSCM NO		l	DWG NO	REV
Checked By:	SCALE	NTS	Date:		SHEET	

APPENDIX B: STRUCTURAL

B.1 Structure Worksheet—WKS1

If array is roof mounted

This section is for evaluating roof structural members that are site built. This includes rafter systems and site built trusses. Manufactured truss and roof joist systems, when installed with proper spacing, meet the roof structure requirements covered in item 2 below.

- 1. Roof construction: 🗆 Rafters 🗆 Trusses 🗆 Other: _____
- 2. Describe site-built rafter or or site-built truss system.
 - a. Rafter Size: ____ x ____ inches
 - b. Rafter Spacing: _____ inches
 - c. Maximum unsupported span: _____ feet, _____ inches
 - d. Are the rafters over-spanned? (see the IRC span tables in **B.2**.) \Box **Yes** \Box **No**
 - e. If *Yes*, complete the rest of this section.

3. If the roof system has

- a. over-spanned rafters or trusses,
- b. the array over 5 lbs/ft^2 on any roof construction, or
- c. the attachments with a dead load exceeding 45 lbs per attachment;
- it is recommended that you provide one of the following:
 - i. A framing plan that shows details for how you will strengthen the rafters using the supplied span tables in B.2.
 - ii. Confirmation certified by a design professional that the roof structure will support the array.

If array is ground mounted:

- 1. Show array supports, framing members, and foundation posts and footings.
- 2. Provide information on mounting structure(s) construction. If the mounting structure is unfamiliar to the local jurisdiction and is more than six (6) feet above grade, it may require engineering calculations certified by a design professional.
- 3. Show detail on module attachment method to mounting structure.



B.2 Span Tables

A framing plan is required only if the combined weight of the PV array exceeds 5 pounds per square foot (PSF or lbs/ft²) or the existing rafters are over-spanned. The following span tables from the 2009 International Residential Code (IRC) can be used to determine if the rafters are over-spanned. For installations in jurisdictions using different span tables, follow the local tables.

Span Table R802.5.1(1),

10 PSF Dead Load Roof live load = 20 psf, ceiling not attached to rafters, L/ Δ =180									
	2 x 4	2 x 6	2 x 8	2 x 10	2 x 12				
Spacing (inches)	Species	Grade	The measurements below are in feet-inches (e.g. 9-10 = 9 feet, 10 inches).						
16	Douglas Fir-larch	#2 or better	9-10	14-4	18-2	22-3	25-9		
16	Hem-fir	#2 or better	9-2	14-2	17-11	21-11	25-5		
24	Douglas Fir-larch	#2 or better	8-0	11-9	14-10	18-2	21-0		
24	Hem-fir	#2 or better	7-11	11-7	14-8	17-10	20-9		

Use this table for rafter spans that have conventional light-weight dead loads and do not have a ceiling attached.

Use this table for rafter spans that have heavy dead loads and do not have a ceiling attached.

20 PSF Dead Load Roof live load = 20 psf, ceiling not attached to rafters, L/ Δ =180									
	Ą	Rafter Size	2 x 4	2 x 6	2 x 8	2 x 10	2 x 12		
Spacing (inches)	Species	Grade	The measurements below are in feet-inches (e.g. 9-10 = 9 feet, 10 inches).						
16	Douglas Fir-larch	#2 or better	8-6	12-5	15-9	19-3	22-4		
16	Hem-fir	#2 or better	8-5	12-3	15-6	18-11	22-0		
24	Douglas Fir-larch	#2 or better	6-11	10-2	12-10	15-8	18-3		
24	Hem-fir	#2 or better	6-10	10-0	12-8	15-6	17-11		

Span Table R802.5.1(2),

Use this table for rafter spans with a ceiling attached and conventional light-weight dead loads.

10 PSF Dead Load Roof live load = 20 psf, ceiling attached to rafters, L/Δ =240									
Rafter Size 2 x 4 2 x 6 2 x 8 2 x 10 2 x 12									
Spacing (inches)	Species	Grade	The measurements below are in feet-inches (e.g. 9-10 = 9 feet, 10 inches).						
16	Douglas Fir-larch	#2 or better	8-11	14-1	18-2	22-3	25-9		
16	Hem-fir	#2 or better	8-4	13-1	17-3	21-11	25-5		
24	Douglas Fir-larch	#2 or better	7-10	11-9	14-10	18-2	21-0		
24	Hem-fir	#2 or better	7-3	11-5	14-8	17-10	20-9		

Use this table for rafter spans with a ceiling attached and where heavy dead loads exist.

20 PSF Dead Load									
Roof live load = 20 psf, ceiling attached to rafters, L/Δ =240									
Rafter Size 2 x 4 2 x 6 2 x 8 2 x 10 2 x 12									
Spacing (inches)	Species	Grade	The measurements below are in feet-inches (e.g. 9-10 = 9 feet, 10 inches).						
16	Douglas Fir- larch	#2 or better	8-6	12-5	15-9	19-3	22-4		
16	Hem-fir	#2 or better	8-4	12-3	15-6	18-11	22-0		
24	Douglas Fir- larch	#2 or better	6-11	10-2	12-10	15-8	18-3		
24	Hem-fir	#2 or better	6-10	10-0	12-8	15-6	17-11		

Use the conventional light-weight dead load table when the existing roofing materials are wood shake, wood shingle, composition shingle, or light-weight tile. (The rationale for allowing these tables to be used is that the installation of a PV system should be considered as part of the live load, since additional loading will not be added to the section of the roof where a PV array is installed.)

Where heavy roofing systems exist (e.g. clay tile or heavy concrete tile roofs), use the 20 lbs/ft^2 dead load tables.

