



FIRE LANES

FIRE LANE -

City Ordinance #2435 and International Fire Code Chapter 5, Section 503.3 as amended.

Fire apparatus access roads "Fire Lanes" shall be identified by painting the curb yellow and a four inch wide line and block letters 18 inches high, painted in the lane, at fifty foot intervals, stating, "FIRE LANE NO PARKING", color to be bright yellow, or by the posting of signs stating, "FIRE LANE NO PARKING", and painting the curb. Signs shall be posted on or immediately next to the curb line or on the building. Signs shall be twelve inches by eighteen inches

and shall have letters and background of contrasting color, readily readable from at least a fifty foot distance. Signs shall be spaced not further than fifty feet apart nor shall they be more than four feet from the




FIGURE D103.6
FIRE LANE SIGNS