

FIRE DEPARTMENT SUBMITTAL REQUIREMENTS FOR FIRE SUPPRESSION SYSTEMS

All required documents need to be uploaded and all permit fees need to be paid for a complete application submittal to be processed.

COMMERCIAL FIRE SPRINKLER PERMITS

REQUIRED DOCUMENTS (All files to be Portable Document Format - PDF):

- SCALED PLANS (1" = 20')
- CUT SHEETS
- SPRINKLER CALCULATIONS
- Copy of WA STATE SPRINKLER CONTRACTOR LICENSE
- OUTSIDE REVIEW provided by WA State Licensed Fire Protection Engineer (F.P.E) if Sprinkler projects involved more than 50 heads.

RESIDENTIAL 13D FIRE SPRINKLER PERMITS

REQUIRED DOCUMENTS (All files to be Portable Document Format - PDF):

- SCALED PLANS (1" = 20')
- CUT and COMPATIBILITY SHEETS for the following types of products to be used:
 - Sprinkler Pipe
 - Sprinkler Head
 - Thread Sealant
 - Caulking
 - Cleaner
 - Fire Stop Product
 - Duct Sealant
- SPRINKLER CALCULATIONS
- Copy of WA STATE SPRINKLER CONTRACTOR LICENSE

KITCHEN HOOD UL300 SUPPRESSION PERMITS

REQUIRED DOCUMENTS (All files to be Portable Document Format - PDF):

- SCALED PLANS (1" = 20')
- CUT SHEETS
- SPRINKLER CALCULATIONS
- Copy of WA STATE SPRINKLER CONTRACTOR LICENSE

CLEAN AGENT SUPPRESSION PERMITS

REQUIRED DOCUMENTS (All files to be Portable Document Format - PDF):

- SCALED PLANS (1" = 20')
- CUT SHEETS
- SPRINKLER CALCULATIONS
- Copy of WA STATE SPRINKLER CONTRACTOR LICENSE
- OUTSIDE REVIEW provided by WA State Licensed Fire Protection Engineer (F.P.E) if Sprinkler projects involved more than 50 heads.